


Waterworks damage







Yasuko Kuwata
Dept. of Civil Eng., Kobe University


Ground motion and water outage




Seismic intensity (JMA)




Restoration process (Miyagi Pref.)



Restoration process (except Miyagi Pref.)



Restoration process in the Kobe EQ




Damage pattern and regional characteristic

□ Tohoku area (Miyagi Pref.)

- Destructive tsunami damage at coastal area
- Large diameter pipe damage
- Local damage due to liquefaction
- Minor damage to small diameter pipeline

□ Kanto area (Chiba/Ibaraki Pref.)

- Moderate seismic intensity
- Wide-area liquefaction damage



Damage to water supply facility Miyagi pref.



Destructive tsunami damage at coastal area

Large diameter pipe damage

Local damage due to liquefaction

Minor damage to small diameter pipeline

Large diameter pipe damage/ Shiraishi



River under-passing
transmission pipeline SP ϕ 2400



After recovery

Lateral sliding 70 cm

Large diameter pipe damage/ Shiraishi



(March 28, Google Earth)

River under-passing
transmission pipeline SP ϕ 2400



Large diameter pipe damage/ Shiraishi




Joint at SP ϕ 1200, damaged by April 7, aftershock

Large diameter pipe damage/ Sendai



Water leak at welded part of steel pipe,
Sendai: SP ϕ 700 damaged by April 7,
aftershock




Large diameter pipe damage/ Sendai



Water leak at welded part of steel pipe, Sendai: SP ϕ 700 damaged by April 7, aftershock

Large diameter pipe damage/ Osaki



Water leak from joints at bending part DIP ϕ 500, damaged by April 7 aftershock

Pipe bridge damage/ Misato



Tilting pier

Eai river right side



Eai river left side



Water leak from joint

Slide of embankment at water pipe bridge ($\phi 500$) and water leak from flexible joint, after April 4 aftershock

Pipe damage, Natori



DIP ϕ 300, damaged by April 7 aftershock



Before April 7



Crack on pipe body

Pipeline damage due to ground deformation



Midorigaoka, Sendai



Oritate, Sendai



Furukawa, Osaki

Land deformation at hill-side land development

Liquefaction



Sakuragaoka, Sendai



Sakuragaoka, Sendai



Furukawa, Osaki



Temporal repair of water pipe bridge.

How much performance is required in temporary repair?

Speed? Or performance?

Consideration for strong aftershocks



Water pipe bridge in Osaki, Miyagi Pref.

Water pipe bridge/ adjusted pipe



Minami sanriku



Bearing of water pipe bridge Osaki



Sendai



Kesennuma

Damage to water supply facility Ibaraki/ Chiba prefs.



Moderate seismic ground motion

Wide-area liquefaction damage to facility and
pipeline



画像取得日: 2011年3月29日 35° 54'32.74" N 140° 35'42.20" E 標高 0 m 高度 19.99 km

Liquefied area around Kamisu/ Kashima



(March 12, Google Earth)

Wanigawa purification plant



(March 12, Google Earth)

Damage at Wanigawa purification plant



Liquefaction surrounding pump facility

Damage at Wanigawa purification plant



Liquefaction damage

Common duct 50 cm lift up

Surround ground 50 cm subsidence

Pipe connection to facility



Damage to flexible joint, DIP ϕ 600, by subsidence due to liquefaction at the connection to the facility



Subsidence/ No subsidence



Foundation of Electric power



Distribution reservoir



Later leak at joint of DIP(K) ϕ 300




Crack and subsidence due to liquefaction



Water leak from bellow's type flexible joint

Pipeline damage due to wide-area liquefaction/ Itako, Ibaraki



Pipeline damage due to wide-area liquefaction/ Kamisu, Ibaraki



Pipeline damage due to wide-area liquefaction/ Katori, Chiba



Lift up of water storage tank by liquefaction



Storage tank was constructed for disaster

Water storage tank 100m³, Urayasu, Chiba

Other damage in Ibaraki/ Chiba areas



Water storage 100m³/ Urayasu



Firefighting water storage
40m³/ Asahi



Asahi

Uplifted tanks in liquefied ground



Hitachi



Leak of SP φ 250

Pipe at sliding bearing of pipe beam bridge hit at walls

Other pipeline damage




Pipeline damage, DIP ϕ 150, due to landslide



Pipeline damage, DIP(A) ϕ 350, due to raised ground surrounding underpass of highway embankment

Why does it take long restoration in Ibaraki?

- Interruption of water transmission because of liquefaction of purification plant and distribution plant
- Wide-area water transmission supply
 - Rokko wide water supply
- Less redundancy of large-diameter transmission pipe
- Difficulty of pipe repair at wide-area liquefaction



//ISSUE//

- Revaluation of liquefaction at coastal area
- Install of flexible pipe at developed land of residence

Rokko wide water supply

Future tasks on structural problem

- Seismic measures of large-diameter pipe
 - Seismic performance of welded part and joint of large-diameter pipe
 - Seismic behavior of underpass, curve, fixed parts of pipeline
 - Seismic performance of water pipe bridge
- Wide-area liquefaction mechanism and its measures
 - Peak ground motion plus duration of ground motion
 - Evaluation of important facilities against long-period ground motion
 - Intake structure of embankment
 - Subsidence surrounding facilities
 - Uplift measures of common duct and drain
 - Pipe connecting to facilitate
 - Flexible pipe install at liquefaction area
 - Uplift measures of water tanks
- High-level aftershock measures
 - Damaged earth structures, temporal repaired structures

Future tasks on functional problem

- Black out measures
 - A few days black-out causes delay of water supply (damage identification, filling water in reservoir and large-diameter pipeline).
- Redundancy of transmission and delivery main pipeline
 - Wide-area water transmission system with less redundancy
 - Two systems (regional and local)
 - Multi water resources
 - No enhancement of small and old systems
- Water storing by shut-off valves
 - Saving water by automatically or manually
- Emergency connection pipelines between cities
 - Not efficient in this event, because wide-area disaster

Future tasks on recovery in wide earthquake disaster

- Suffered water department staffs
 - Half of staffs was Isolated in the sea for a night
- Early response of emergency water delivery
 - Lessons from recent earthquakes.
 - Dispatched from JWVA, other cities.
 - Malfunction of information management by chief government in Tohoku, Kanto district
- Recovered by local workers, not dispatched workers
- Securing supply-chain of materials
 - Pipe, equipment, fuel, vehicle, roadway
- Decision making of recovery strategy in liquefaction zone
 - Repair/ Install with above pipeline
- Lack of engineers in local government
 - Reducing engineers in last decade.

Thank you for your attention!!!

